

SERTİFİKA

CERTIFICATE 证书 ZERTIFIKAT प्रमाण-पत्र CERTIFICATO

**EC Pressure Equipment Directive
(97/23/EC)**

European Notified Body Ref
1984

Certificate of Quality System Approval

This is to certify that the:

Pressure Equipment

As described below

**Name and Address of
Manufacturer
(or Authorised Representative)**

KALDERA İSITMA SİSTEMLERİ SAN ve
TİC.LTD.ŞTİ

Equipment Description

Organize Sanayi Bölgesi Demirciler Sitesi
75.Yıl Cad G Blok No:3 Nilüfer /BURSA/ TURKEY
For heating system of hot water, cast iron sectional
manually loading, standard thermostatically
controlled or with fan controlled, solitem trade
model solid fuel boilers as listed on the Schedule to
this Certificate

Pressure

4 Bar

Temperature

Max. +100 °C

Standards applied

EN 303 - 5

Category

III

Report Reference

MEYER-PED-0111-KLD-02

This approval is subject to annual surveillance audits and verifications by MEYER as required by the relevant conformity assessment module of the Pressure Equipment Directive, and may be subject to such audits being unannounced. This Certificate is valid in any European Economic Area Member State. This certificate has been issued by MEYER which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive (Notified Body number 1984).

This certificate is issued following the assessment of the documentation and implementation of the Quality System in accordance with the provisions of the quoted Conformity Assessment module of the above Directive. The CE Mark may be affixed to the pressure equipment within the scope of approval as described above once the EC Declaration of Conformity has been made by the responsible person. The number '1984', being MEYER's Notified Body number, should also be placed on the equipment dataplate.


Certificate No:1984-PED-11-002

Issue Date: 06.01.2011



MEYER CERTIFICATION SERVICES INCORPORATION
İTOSB 9. Cad. No:15 Tepeören-Tuzla / İSTANBUL-TÜRKİYE
Tel.: +90 216 593 25 75 , Fax: +90 216 593 25 74
Web: www.meyer.gen.tr , e-mail: posta@meyer.gen.tr

Certificates without seal are invalid


M. Gökhan Yücel
Head of Notified Body

I.P.CR.008 R2
Page 1 of 2

SERTIFIKA

CERTIFICATE 证书 ZERTIFIKAT प्रमाण-पत्र CERTIFICATO

Schedule to Certificate No 1984-PED-11-002

| Model | Capacity |
|--|----------|
| ST 5F with fan controlled | 34 kW |
| ST 6F with fan controlled | 41 kW |
| ST 7F with fan controlled | 48 kW |
| ST 8F with fan controlled | 56 kW |
| ST 10F with fan controlled | 70 kW |
| ST 3S Standard thermostatically controlled | 17 kW |
| ST 4S Standard thermostatically controlled | 27 kW |
| ST 5S Standard thermostatically controlled | 34 kW |
| ST 6S Standard thermostatically controlled | 41 kW |
| ST 7S Standard thermostatically controlled | 48 kW |
| ST 8S Standard thermostatically controlled | 56 kW |

End of Schedule to Certificate No 1984-PED-11-002



MEYER CERTIFICATION SERVICES INCORPORATION
İTOSB 9. Cad. No:15 Tepeören-Tuzla / İSTANBUL-TÜRKİYE
Tel.: +90 216 593 25 75 , Fax: +90 216 593 25 74
Web: www.meyer.gen.tr , e-mail: posta@meyer.gen.tr

Certificates without seal are invalid

I.P.CR.008 R2
Page 2 of 2