

Bureau Veritas Consumer Products Services Germany GmbH

Businesspark A96 86842 Türkheim Germany + 49 (0) 40 740 41 – 0 cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH Accredited according to EN 45011 -ISO / IEC Guide 65

Certificate of compliance

Applicant: SHENZHEN GROWATT

NEW ENERGY TECHNOLOGY CO., LTD.

1st East & 3rd Floor, Building 5, Jiayu Industrial Zone, Xibianling, Shangwu Village, Shiyan, Baoan District,

Shenzhen, **P.R.China**

Product: Automatic disconnection device between a generator and

the public low-voltage grid

Model: Growatt 1000

Growatt 1000S Growatt 1500 Growatt 1500S Growatt 2000 Growatt 3000

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2006-02 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report number: PVDE120627N004-VDE0126

Certificate number: U14-0220
Date of issue: 2014-04-01

Certification body

Dieter Zitzmann



SOCIAL

Akkreditierungsstelle D-ZE-12024-01-01