



ZHEJIANG FOTECH INTERNATIONAL CO., LTD.
浙江孚泰科技有限公司

CERTIFICATE OF ANALYSIS

Product: REFRIGERANT R-1234YF

Source of sample: steel cylinder

Batch number: 00018204R1234YF

Certificate date: July 11, 2018

Testing Criteria: GB/T 18826-2002

RESULTS OF ANALYSIS

ANALYSIS ITEMS	STANDARD (EXCELLENT)	RESULTS
Appearance	Colorless and clearness	Colorless and clearness
Odor	Odorless	Odorless
Purity (% by weight)	99.9Min.	99.95
Moisture (% by weight)	10Max.	6.2
Acidity (% by weight)	0.1 Max.	<0.1
Chlorineion test	Pass	Pass
Non-Condensable	1.5Max	0.37
High Boiling Residue (% by weight)	100 Max.	8.7
Other HFCs (ppm by volume)	200 Max	Pass
Final conclusion: Conformity		

Results: the products tested reach the excellent grade.

Analyst:

浙江孚泰科技有限公司
Zhejiang Fotech International Co., Ltd

Tel: 0086-571-87918266 Fax: 0086-571-87089366