



**New Website Coming Soon**

### Specific Point Evaluation for H2BG124DBE

Measurement System: Metric

Revision: 1

Refrigerant: R22

Series Family: G

		Valid Temperature Range
Condenser Temperature	40 °C	25°C to 65°C
Evaporator Temperature	-5 °C	-30°C to 10°C
Enter the subcool amount [Default is 8.33°C]	8.33	0°C to 27.8°C
Enter the Superheat amount [Default is 11.11°C]	11.11	0°C to 27.8°C

Specific point values based on data above:

Capacity                      18 100 Watts

Power                            6 770 Watts

EER                                2.7 COP

Copyright © 2013 Bristol Compressors International, Inc. All rights reserved.