





1	Earthing Terminals
2	Cooling Panel
3	H.V Bushing/ 20 NF 250 A
4	L.V Bushing/ 1kV 630A
5	Thermometer
6	Pressure Relief Valve
7	Oil Drain Valve
8	Oil Filling Valve
9	Tap Changer
10	Rating Plate
11	Lifting Lugs
12	Oil Level Indicator

A		Drawing No : 25-1304-400					Project :	Order No :	XT Serial No :	DESIGNED		CONTROL	APPROVED	A	
										G.ÖZAYDINLI	Abuzer ÇABUK				
		Scale -/-		Page 1/2	Total 2	Size A4	All Dimensions Milimeter.		XTO : 400 kVA 10-0,4 kV Technical Drawing						
							All Dimensions With ±%10 Tolarence								
8		7		6		5		4		3		2		1	