





- | | |
|----|----------------------------|
| 1 | Earthing Terminals |
| 2 | Cooling Panel |
| 3 | H.V. Bushing / 20NF 250A |
| 4 | L.V. Bushing / 1 kV 1000 A |
| 5 | Wheels |
| 6 | Hermetic Pressure Valve |
| 7 | Lifting Lugs |
| 8 | Oil Drain Valve |
| 9 | Oil Filling Valve |
| 10 | DGBT Relay |
| 11 | Rating Plate |
| 12 | Tap Changer |
| 13 | Terminal Box |
| 14 | Antimagnetic Sheet |

Project :	Order No :	XT Serial No :	DESIGNED		CONTROL	APPROVED
				G.ÖZAYDINLI	Abuzer ÇABUK	
All Dimensions Milimeter.			XTO : 630 kVA 10-0,4kV Technical Drawing			
All Dimensions With ±%10 Tolarence						



Drawing No : 25-1307-630

Scale
-/-



Page
1/2

Total
2

Size
A4